

Day	pH	Alk	Comments	Y/N
1				
2				
3				
4				
5				
6	7.61	160		y
7				
8				
9				
10				
11				
12				
13	7.59	160		y
14				
15				
16	7.61	160		y
17	7.50	-		y
18				
19	7.27	-		
20	7.43	160		y
21				
22				
23	7.57	160		y
24				
25				
26				
27	7.55	160		y
28				
29				
30	7.49	160		y
31				

(No = N = Excursion) Total N's **8**

<<Have minimums been met for this day? **Y**

ENTRY POINT

PWS ID: 41 **00508**

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: October 2025
Month/Year

Number of excursions* during this month: **8**
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: **8**
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0
Alk	45.0
PO4	--
Other	--

(Alkalinity)
(Orthophosphate)

Eric Carlson 11/5/25

Print Name: Jeffrey H. Carlson

Signature: JKC

Date: 10/30/25

Send to DWP within 10 days after end of sampling period