

Day	pH	Alk	Comments	Y/N
1	7.26	160		y
2	7.71	160		y
3				
4				
5				
6				
7	7.51	—		y
8	7.55	160		y
9	7.62	160		y
10				
11				
12				
13				
14	8.06	—		y
15	7.42	160		y
16	7.29	—		y
17				
18				
19				
20				
21				
22	8.00	160		y
23				
24				
25				
26				
27				
28				
29				
30	8.00	120		y
31	7.53	120		y

'No = N = Excursion) Total N's 8

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 **00508**

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: December 2025  
Month/Year

Number of excursions\* during this month: 8  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 15  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	( )

Eric Carlson 1/5/26

Print Name: Jeffrey A. Carlson

Signature: JKC

Date: 1/3/26

Send to DWP within 10 days after end of sampling period