

Day	pH	Alk	Comments	Y/N
1				
2				
3	8.52	-		y
4				
5	7.65	120		y
6				
7				
8	7.40	-		y
9				
10				
11				
12				
13	7.31	100		y
14				
15				
16				
17	7.19	120		y
18				
19				
20	7.56	100		y
21				
22	7.72	-		y
23				
24				
25				
26	7.28	100		y
27				
28				
29				
30				
31				

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: January 2026
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	(_____)

2/3/26 Eric Carlson

Print Name: [Signature]

Signature: _____

Date: 2/3/26

Send to DWP within 10 days after end of sampling period

(N = Excursion) Total N's

- IN PEN -