

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk mg/L	Y/N
1			
2			
3			
4	6.98	50	Y
5			
6			
7			
8			
9			
10			
11	6.97	47	Y
12			
13			
14			
15			
16			
17			
18	6.99	48	Y
19			
20			
21			
22			
23			
24			
25	7.00	51	Y
26			
27			
28			
29			
30			
31			
Min	6.97		
Total N's			0

(No = N = Excursion)

<< Have
minimums
been met for
this day?

ENTRY POINT

PWD ID: OR 4100513

System Name:	Medford Water Commission	
Entry Point:	A	
Sample Period:	October, 2021	

Month/Year

Number of excursions* during this month:

0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:

0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance?

Yes

**Minimum Water Quality
Parameters as set by State:**

pH 6.8

Print Name: Dan Perkins

Signature:

Dan Perkins

Date:

11/3/2021

Send to DWP within 10 days after end of sampling period.
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>
Email dwp.dmce@state.or.us