



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

| Day | pH | Alk mg/L | Y/N |
|-----------|------|-------------|----------|
| 1 | | | |
| 2 | | | |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | 6.92 | 52 | Y |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | 7.03 | 49 | Y |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | 6.96 | 49 | Y |
| 20 | | | |
| 21 | | | |
| 22 | | | |
| 23 | | | |
| 24 | | | |
| 25 | | | |
| 26 | 6.92 | 48 | Y |
| 27 | | | |
| 28 | | | |
| 29 | | | |
| 30 | | | |
| 31 | | | |
| Min | 6.92 | | |
| Total N's | | | 0 |

(No = N = Excursion)

<< Have minimums been met for this day?

ENTRY POINT

PWD ID: OR 4100513

| | |
|-----------------------|---------------------------------|
| System Name: | Medford Water Commission |
| Entry Point: | A |
| Sample Period: | September, 2022 |

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Yes

**Minimum Water Quality
Parameters as set by State:**

pH 6.8

Print Name: Dan Perkins

Signature:

Dan Perkins

Date:

 10/4/2022

Send to DWP within 10 days after end of sampling period.
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>
Email dwp.dmce@state.or.us