

## Water Quality Parameter Monitoring Form

## **Lead & Copper Rule Corrosion Control**

Day	рН	Alk mg/L	Y/N	<< Have minimums been met for	ENTRY POINT				
1				this day?					
2	6.96	51	- V	PWD ID: OR 4100513					
	0.90	51	Υ						
5				System	System Name:		Medford Water Commission		
6									
7				Entry Po	Entry Point:				
8									
9				Sample	Sample Period:		July, 2023		
10				Month/Year  Number of excursions* during this month:  (Count the number of days when any WQP was less than the					
11	6.98	50	Υ						
12									
13				minimum	required)				
14				Total excursions during the previous 5 months: 0					
15				(Over 9 excursions in 6 months is a violation. Entry Point and					
16				Distribution excursions are cumulative)					
17	6.97	50	Υ				1		
18				Is system in compliance? Yes					
19				10 0 7 0 10 1	., 00	, and	103		
20									
21					Minimum Water Quality Parameters as set by State:				
22									
23	C 0C	40	V						
24	6.96	48	Υ		pH 6.8				
25 26						•			
27									
28									
29				Print Na	Print Name: Matt Severloh				
30				1 11116 146	-				
31	6.98	51	Υ	Signatu	re:	Matt	Seversh		
Min	6.96				1.5				
otal N's 0			0	Date:		8/1/2023			

(No = N = Excursion)

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/ Email dwp.dmce@state.or.us