

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pН	Alk mg/L	Y/N	<< Have minimums been met for	ENTRY POINT			
1				this day?				
2					PWI	D ID: C	OR 4100513	
4	6.97	51	Υ	Construct No.		24 17 124		
5				System Name:		Medford Water Commission		
6				Entry Point:		Α		
7				Liitiy	onit.	A		
8				Sample	Period:	Dec	cember, 2023	
9				Sample	i ciioa.			
10				Month/Year				
11	6.99	50	Υ	Number of excursions* during this month: 0				
12				(Count the number of days when any WQP was less than the				
13				minimun	n required)		p	
14				Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)				
15								
16								
17								
18	6.98	51	Υ	Is system in compliance? Yes				
19				13 54500		Jiidiice.	163	
20			-					
21					Minimum Water Quality			
22					Parameters as set by State:			
23							-	
24				pH 6.8				
25						P''		
26	6.87	53	Υ					
27								
28				Duine At		V 4 - 4 - C	aulala	
29				Print Na	ame:	Matt Se		
30	_			Sianatu	ro	my	SeverSh	
31	C 07			Signatu	ie:	1 4/0	Denersh	
Min 6.87		Data		1/1/2024				
Total N's 0 (No = N = Excursion)			0	Date:				

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/ Email dwp.dmce@state.or.us