

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk mg/L	Y/N	<< Have minimums been met for	ENTRY POINT				
1				this day?					
2					P\\/\[יווי כ	OR 4100513		
3					IVVL) ID. C)II 4100313		
4	7.36	59	Υ	System Name:		Medford Water Commission			
5									
6				Entry Po	oint:	Α			
7									
8				Sample Period:		N	1arch, 2024		
9									
10	7.10	63	\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	Month/Year Number of excursions* during this month: (Count the number of days when any WQP was less than the minimum required) Total excursions during the previous 5 months: (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)					
11	7.19	63	Υ						
12 13									
14 15									
16									
17									
18	7.19	63	Υ						
19	7.13	03	1	Is system in compliance? Yes					
20									
21					Min	imum V	Vator Quality		
22				Minimum Water Quality Parameters as set by State:					
23									
24									
25	7.22	59	Υ		pH 6.8				
26									
27									
28									
29				Print Na	me:	Matt Se	everloh		
30					-				
31				Signatu	re:	maxt	Severth		
Min	7.19								
Total N's 0			0	Date:		4/1/2024			

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/ Email dwp.dmce@state.or.us