

WARNING - All data does not meet minimum data approval for report (-4096)



## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk mg/L	Y/N
1	7.89	48	Y
2			
3	7.76	68	Y
4			
5			
6			
7			
8			
9			
10	7.72	67	Y
11			
12			
13			
14			
15			
16			
17	7.74	65	Y
18			
19			
20			
21			
22			
23			
24	7.64	66	Y
25			
26			
27			
28			
29			
30			
31			
Min	7.64		
Total N's			<b>0</b>

(No = N = Excursion)

<< Have minimums been met for this day?

### ENTRY POINT

**PWD ID: OR 4100513**

**System Name:** Medford Water Commission

**Entry Point:** A

**Sample Period:** June, 2024

Month/Year

**Number of excursions\* during this month:** 0

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

**Is system in compliance?** Yes

**Minimum Water Quality  
Parameters as set by State:**

**pH 6.8**

**Print Name:** Matt Severloh

**Signature:** *Matt Severloh*

**Date:** 7/2/2024

Send to DWP within 10 days after end of sampling period.  
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>  
Email [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us)