



## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk mg/L	Y/N
1	7.90	49	Y
2			
3	7.72	69	Y
4			
5			
6	7.87	45	Y
7			
8			
9	7.66	65	Y
10			
11			
12			
13			
14			
15			
16	7.71	68	Y
17			
18			
19			
20			
21			
22			
23	7.59	66	Y
24			
25			
26			
27			
28			
29			
30			
31			
Min	7.59		
Total N's			<b>0</b>

(No = N = Excursion)

<< Have minimums been met for this day?

### ENTRY POINT

**PWD ID: OR 4100513**

<b>System Name:</b>	<b>Medford Water Commission</b>
<b>Entry Point:</b>	<b>A</b>
<b>Sample Period:</b>	<b>September, 2024</b>

Month/Year

**Number of excursions\* during this month:**   
 (Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:**   
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

**Is system in compliance?**

**Minimum Water Quality Parameters as set by State:**

**pH 6.8**

**Print Name:**           Matt Severloh          

**Signature:**           *Matt Severloh*          

**Date:**           10/1/2024          

Send to DWP within 10 days after end of sampling period.  
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>  
 Email [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us)