

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pН	Alk mg/L	Y/N	<< Have minimums been met for	ENTRY POINT				
1				this day?					
2					P\\/I	י חור	OR 4100513		
3					1 771	J ID. (JI 4100313		
5				System Name:		Medford Water Commission			
6	7.59	71	Υ	Entry Point:		Α.			
7				Entry P	oint:	Α			
8	7.64	59	Υ	Camanla	Davia da		2025		
9				Sample	Period:	Ja	nuary, 2025		
10				Month/Year Number of excursions* during this month: (Count the number of days when any WQP was less than the minimum required) Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)					
11									
12									
13	7.62	68	Υ						
14									
15									
16									
17									
18				Is system in compliance? Yes					
19				13 3936	iii iii com	manice:	163		
20					-			1	
21	7.69	69	Υ	Minimum Water Quality					
22	7.84	58	Υ		Parameters as set by State:				
23							-		
24				8.6 Hq					
25						þi	1 0.0		
26									
27	7.74	68	Υ						
28									
29				Print Na	ame:	Matt Se	everloh		
30						20 11	0 01		
31				Signatu	re:	Matt	-SeverSh		
Min 7.59					2/1/2025				
Total N's 0			0	Date:			2, 1, 2025		

(No = N = Excursion)

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/ Email dwp.dmce@state.or.us