

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pН	Alk mg/L	Y/N	<< Have minimums been met for	minimums ENTRY POI			
1				this day?				
2					P\\/I	ים ו	OR 4100513	
3						J 1D. (JK 4100313	
4				System Name:		Medford Water Commission		
5	7.66	69	Υ	, , , , , , , , , , , , , , , , , , , ,			Toru Truter Com	
6				Entry Point:		Α		
7	7.77	54	Υ			,,		
8				Sample	Period:	Fe	bruary, 2025	
9								
10	7.70	66	Υ	Month/Year				
11				Number of excursions* during this month: 0				
12				(Count the number of days when any WQP was less than the				
13			-		n required)			
14			-	Total excursions during the previous 5 months: 0				
15							ns is a violation. Entry P	oint and
16				Distributi	on excursic	ns are cu	mulative)	
17	7.74		1					
18	7.74	68	Υ	Is system in compliance? Yes				
19				•				
20 21	7.78	61	V				A1	
_	7.70	91	Υ		Minimum Water Quality			
22					Paran	neters a	as set by State:	
24	7.49	66	Υ					
25	7.49	00	Ť		pH 6.8			
26								
27								
28								
29				Print Na	ame.	Matt Se	everloh	
30				r mic ive				
31	_			Signatu	re:	MAH	Severel	
Min	7.49			2.8		1 am	NO VOIN	
			0	Date:		3/1/2025		
		= Excursio						

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/ Email dwp.dmce@state.or.us