



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk mg/L	Y/N
1			
2			
3			
4			
5	7.50	65	Y
6			
7			
8			
9			
10			
11			
12	7.57	45	Y
13			
14			
15			
16			
17			
18			
19	7.64	65	Y
20			
21			
22			
23			
24			
25			
26			
27	7.69	65	Y
28			
29	7.84	45	Y
30			
31			
Min	7.50		
Total N's			0

(No = N = Excursion)

<< Have
minimums
been met for
this day?**ENTRY POINT****PWD ID: OR 4100513****System Name:** Medford Water Commission**Entry Point:** A**Sample Period:** May, 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Yes**Minimum Water Quality
Parameters as set by State:****pH 6.8****Print Name:** Matt Severloh**Signature:***Matt Severloh***Date:**

6/1/2025

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>Email dwp.dmce@state.or.us