



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk mg/L	Y/N
1			
2	7.84	63	Y
3			
4			
5			
6			
7			
8			
9			
10	7.74	66	Y
11			
12			
13			
14			
15			
16	7.77	64	Y
17			
18			
19			
20			
21			
22			
23	7.81	63	Y
24	7.80	49	Y
25			
26			
27			
28			
29			
30	7.82	64	Y
31			
Min	7.74		
Total N's			0

(No = N = Excursion)

<< Have
minimums
been met for
this day?

ENTRY POINT

PWD ID: OR 4100513

System Name: Medford Water Commission

Entry Point: A

Sample Period: June, 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Yes

Minimum Water Quality
Parameters as set by State:

pH 6.8

Print Name: Matt Severloh

Signature:

Date:

7/1/2025

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>

Email dwp.dmce@state.or.us