



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk mg/L	Y/N
1			
2			
3	7.65	64	Y
4			
5			
6			
7			
8			
9			
10	7.60	66	Y
11	7.55	49	Y
12			
13			
14			
15			
16			
17	7.73	63	Y
18			
19			
20			
21			
22			
23			
24	7.64	63	Y
25	7.71	50	Y
26			
27			
28			
29			
30			
31			
Min	7.55		
Total N's	0		

(No = N = Excursion)

<< Have minimums been met for this day?	<b>ENTRY POINT</b>	
	<b>PWD ID: OR 4100513</b>	
System Name:	Medford Water Commission	
Entry Point:	A	
Sample Period:	November, 2025	

Month/Year

Number of excursions\* during this month:

(Count the number of days when any WQP was less than the  
minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and  
Distribution excursions are cumulative)

Is system in compliance?  Yes

Minimum Water Quality  
Parameters as set by State:

pH 6.8

Print Name: Matt Severloh

Signature:

Date: 12/1/2025

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>

Email [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us)