



## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk mg/L	Y/N
1			
2			
3			
4			
5	7.76	66	Y
6	7.65	60	Y
7			
8			
9			
10			
11			
12	7.61	66	Y
13			
14			
15			
16			
17			
18			
19	7.64	68	Y
20	7.61	58	Y
21			
22			
23			
24			
25			
26	7.63	65	Y
27			
28			
29			
30			
31			
Min	7.61		
Total N's			0

(No = N = Excursion)

<< Have minimums been met for this day?

### ENTRY POINT

**PWD ID: OR 4100513**

**System Name:** Medford Water Commission

**Entry Point:** **A**

**Sample Period:** **January, 2026**

Month/Year

**Number of excursions\* during this month:**

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:**

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

**Is system in compliance?**

**Minimum Water Quality  
Parameters as set by State:**

**pH 6.8**

**Print Name:** Matt Severloh

**Signature:** *Matt Severloh*

**Date:** 2/3/2026

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>

Email [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us)