



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk mg/L	Y/N
1	Plant Off-Line		
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31	↓	↓	↓
Min			
Total N's			0

(No = N = Excursion)

<< Have minimums been met for this day?

ENTRY POINT

PWD ID: OR 4100513

System Name:	Medford Water Commission	
Entry Point:	B	
Sample Period:	February-21	

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance?

YES

Minimum Water Quality Parameters as set by State:

pH **7**

Print Name: Dan Perkins

Signature: Dan Perkins

Date: 3/2/2021

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>

Email dwp.dmce@state.or.us