



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk mg/L	Y/N
1	OFF - Line	↓	
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
Min		✓	
Total N's			0

<< Have minimums been met for this day?

ENTRY POINT

PWD ID: OR 4100513

System Name: Medford Water Commission

Entry Point: B

Sample Period: March, 2023

Month/Year

Number of excursions* during this month:
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance?

**Minimum Water Quality
Parameters as set by State:**

pH 7

Print Name: Dan Perkins

Signature:

Date: 04/01/2023

(No = N = Excursion)

Send to DWP within 10 days after end of sampling period.
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>
 Email dwp.dmce@state.or.us