

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day 1	рН	Alk mg/L	Y/N	<< Have minimums been met for this day?	E	ENTRY POINT		
2		IME			PWD ID: OR 4100513		OR 4100513	
4								
5		0FFL		System	System Name:		Medford Water Commission	
6		1		Entry De	Entry Point:			
7				Entry Po	oint:	В		
8	7.72	33	Υ	Sample	Pariod:		May, 2024	
9				Sample	renou.		IVIAY, 2024	
10							Month/Year	
11				Number of excursions* during this month: 0				
12				(Count the number of days when any WQP was less than the				
13	0.04	27		minimum required)				
14	8.01	37	Υ	Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)				
15								
16 17				Distributio	on excursio	ns are cu	imulative)	
18								
19				Is system in compliance? Yes				
20	7.92	34	Υ					
21					Minimum Water Quality			
22					Minimum Water Quality			
23					Parameters as set by State:			
24								
25					pH 7			
26				2				
27								
28	7.9	32	Υ					
29				Print Na	ıme:	Matt Se	everloh	
30						m	0 01	
31				Signatu	re:	Matt Seroish		
Min							06/01/2024	
Total	N's		0	Date:			30,01,2027	

(No = N = Excursion)

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/ Email dwp.dmce@state.or.us