



## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

| Day       | pH   | Alk<br>mg/L | Y/N |
|-----------|------|-------------|-----|
| 1         | 7.73 | 32          | Y   |
| 2         | 7.91 | 32          | Y   |
| 3         |      |             |     |
| 4         |      |             |     |
| 5         |      |             |     |
| 6         | 7.89 | 33          | Y   |
| 7         |      |             |     |
| 8         |      |             |     |
| 9         | 7.88 | 34          | Y   |
| 10        |      |             |     |
| 11        |      |             |     |
| 12        |      |             |     |
| 13        |      |             |     |
| 14        |      |             |     |
| 15        |      |             |     |
| 16        |      |             |     |
| 17        |      |             |     |
| 18        | 7.66 | 31          | Y   |
| 19        |      |             |     |
| 20        |      |             |     |
| 21        |      |             |     |
| 22        |      |             |     |
| 23        |      |             |     |
| 24        |      |             |     |
| 25        |      |             |     |
| 26        |      |             |     |
| 27        |      |             |     |
| 28        |      |             |     |
| 29        |      |             |     |
| 30        |      |             |     |
| 31        |      |             |     |
| Min       | 7.66 |             |     |
| Total N's |      |             | 0   |

<< Have minimums been met for this day?

### ENTRY POINT

**PWD ID: OR 4100513**

**System Name:** Medford Water Commission

**Entry Point:** B

**Sample Period:** September, 2024

Month/Year

**Number of excursions\* during this month:**

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:**

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

**Is system in compliance?**

**Minimum Water Quality  
Parameters as set by State:**

pH 7

**Print Name:** Matt Severloh

**Signature:** *Matt Severloh*

**Date:** 10/01/2024

(No = N = Excursion)

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>

Email [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us)