



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk mg/L	Y/N
1	7.79	32	Y
2			
3			
4			
5			
6			
7			
8	7.72	35	Y
9			
10			
11			
12			
13	7.85	42	Y
14			
15	7.81	42	Y
16			
17	7.74	33	Y
18			
19			
20	7.80	43	Y
21			
22			
23			
24	7.77	27	Y
25			
26			
27			
28			
29	7.76	46	Y
30			
31	7.52	32	Y
Min	7.52		
Total N's			0

(No = N = Excursion)

<< Have  
minimums  
been met for  
this day?

### ENTRY POINT

PWD ID: OR 4100513

System Name:

Medford Water Commission

Entry Point:

B

Sample Period:

July, 2025

Month/Year

Number of excursions\* during this month:

0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:

0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance?

Yes

Minimum Water Quality  
Parameters as set by State:

pH 7

Print Name:

Matt Severloh

Signature:

*Matt Severloh*

Date:

08/06/2025

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>