



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk mg/L	Y/N
1	6.98	54	Y
2			
3			
4			
5			
6			
7			
8	6.95	50	Y
9			
10			
11			
12			
13			
14			
15	6.94	54	Y
16			
17			
18			
19			
20			
21			
22	6.97	50	Y
23			
24			
25			
26			
27			
28			
29	6.97	48	Y
30			
31			
<b>Min</b>	<b>6.94</b>		
<b>Total N's</b>			<b>0</b>

<< Have minimums been met for this day?

### ENTRY POINT

**PWD ID: OR 4100513**

<b>System Name:</b>	<b>Medford Water Commission</b>
<b>Entry Point:</b>	<b>C</b>
<b>Sample Period:</b>	<b>August, 2022</b>

Month/Year

**Number of excursions\* during this month:** 0

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

**Is system in compliance?**

Yes

**Minimum Water Quality Parameters as set by State:**

**pH 6.8**

**Print Name:** Dan Perkins

**Signature:**

**Date:** 9/8/2022

(No = N = Excursion)

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>  
 Email [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us)