



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk mg/L	Y/N
1			
2			
3			
4			
5			
6			
7	6.98	54	Y
8			
9			
10			
11			
12			
13			
14	6.93	50	Y
15			
16			
17			
18			
19			
20			
21			
22	6.97	51	Y
23			
24			
25			
26			
27			
28	6.94	51	Y
29			
30			
31			
Min	6.93		
Total N's			0

(No = N = Excursion)

<< Have minimums been met for this day?

ENTRY POINT

PWD ID: OR 4100513

System Name:	Medford Water Commission
Entry Point:	C
Sample Period:	August, 2023

Month/Year

Number of excursions* during this month:	0
<small>(Count the number of days when any WQP was less than the minimum required)</small>	
Total excursions during the previous 5 months:	0
<small>(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)</small>	

Is system in compliance? Yes

Minimum Water Quality Parameters as set by State:

pH 6.8

Print Name: Matt Severloh

Signature: *Matt Severloh*

Date: 9/5/2023