

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH 7.80	Alk mg/L	Y/N Y	<< Have minimums been met for	ENTRY POINT				
1				this day?					
2					D\A/F	NID. C	OD 4100E12		
3	7.82	67	Υ	PWD ID: OR 4100513					
4 5				System Name:		Medford Water Commission			
6									
7				Entry Point:		C			
8									
9				Sample Period:		June, 2024			
10	7.71	67	Υ				Month/Year		
11				Number of excursions* during this month: 0					
12				(Count the number of days when any WQP was less than the minimum required) Total excursions during the previous 5 months: (Over 9 excursions in 6 months is a violation. Entry Point and					
13									
14									
15									
16				Distribution e	excursions are c	umulative)			
17	7.70	67	Y						
18					-				
19				Is syster	m in comp	liance?	Yes		
20									
21					Mini	mum V	Vater Quality		
22				Parameters as set by State:					
23					i didilicicio do see by State.				
24	7.77	66	Υ	pH 6.8					
25				pii o.o					
26									
27									
28									
29				Print Na	Print Name:		Matt Severloh		
30					-		0		
31				Signatu	re:	Matt	Seversh		
Min	7.70						7/2/2024		
Total N's 0			0	Date: 7/2/202			1/2/2024		

(No = N = Excursion)

Send to DWP within 10 days after end of sampling period.