



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk mg/L	Y/N
1			
2			
3			
4			
5	7.64	68	Y
6	7.89	51	Y
7			
8			
9			
10			
11			
12	7.79	69	Y
13			
14			
15			
16			
17			
18			
19			
20	7.68	65	Y
21	7.95	45	Y
22			
23			
24			
25			
26	7.71	64	Y
27			
28			
29			
30			
31			
Min	7.64		
Total N's			0

(No = N = Excursion)

<< Have minimums been met for this day?

ENTRY POINT

PWD ID: OR 4100513

System Name:	Medford Water Commission
Entry Point:	C
Sample Period:	August, 2024

Month/Year

Number of excursions* during this month:

0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:

0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance?

Yes

**Minimum Water Quality
Parameters as set by State:**

pH 6.8

Print Name: Matt Severloh

Signature:

 Matt Severloh

Date:

 9/1/2024

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>

Email dwp.dmce@state.or.us