



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

| Day | pH | Alk mg/L | Y/N |
|-----------|------|-------------|----------|
| 1 | | | |
| 2 | | | |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | 7.61 | 66 | Y |
| 7 | | | |
| 8 | 7.66 | 58 | Y |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | 7.60 | 68 | Y |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |
| 21 | 7.68 | 65 | Y |
| 22 | 7.88 | 59 | Y |
| 23 | | | |
| 24 | | | |
| 25 | | | |
| 26 | | | |
| 27 | 7.62 | 66 | Y |
| 28 | | | |
| 29 | | | |
| 30 | | | |
| 31 | | | |
| Min | 7.60 | | |
| Total N's | | | 0 |

(No = N = Excursion)

<< Have minimums been met for this day?

ENTRY POINT

PWD ID: OR 4100513

| | |
|-----------------------|---------------------------------|
| System Name: | Medford Water Commission |
| Entry Point: | C |
| Sample Period: | January, 2025 |

Month/Year

Number of excursions* during this month:

0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:

0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance?

Yes

**Minimum Water Quality
Parameters as set by State:**

pH 6.8

Print Name: Matt Severloh

Signature:

 Matt Severloh

Date:

 2/1/2025

Send to DWP within 10 days after end of sampling period.
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>
Email dwp.dmce@state.or.us