

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk mg/L	Y/N
1	7.73	53	Y
2			
3			
4			
5			
6			
7	7.74	69	Y
8	7.79	52	Y
9			
10			
11			
12			
13			
14	7.65	66	Y
15			
16			
17			
18			
19			
20			
21			
22	7.79	65	Y
23			
24			
25			
26			
27			
28	7.78	64	Y
29			
30			
31			
Min	7.65		
Total N's			0

(No = N = Excursion)

<< Have
minimums
been met for
this day?

ENTRY POINT

PWD ID: OR 4100513

System Name:

Medford Water Commission

Entry Point:

C

Sample Period:

July, 2025

Month/Year

Number of excursions* during this month:

0

(Count the number of days when any WQP was less than the
minimum required)

Total excursions during the previous 5 months:

0

(Over 9 excursions in 6 months is a violation. Entry Point and
Distribution excursions are cumulative)

Is system in compliance?

Yes

**Minimum Water Quality
Parameters as set by State:**

pH 6.8

Print Name:

Matt Severloh

Signature:

Matt Severloh

Date:

8/6/2025

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>

Email dwp.dmce@state.or.us