



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk mg/L	Y/N
1			
2			
3			
4			
5	7.66	64	Y
6			
7			
8			
9			
10			
11	7.72	64	Y
12			
13			
14			
15			
16			
17			
18	7.73	65	Y
19	7.72	44	Y
20			
21			
22			
23			
24			
25	7.72	64	Y
26			
27			
28			
29			
30			
31			
Min	7.66		
Total N's			0

(No = N = Excursion)

<< Have  
minimums  
been met for  
this day?

## ENTRY POINT



PWD ID: OR 4100513

System Name: Medford Water Commission

Entry Point: C

Sample Period: August, 2025

Month/Year

Number of excursions\* during this month:

0

(Count the number of days when any WQP was less than the  
minimum required)

Total excursions during the previous 5 months:

0

(Over 9 excursions in 6 months is a violation. Entry Point and  
Distribution excursions are cumulative)

Is system in compliance?

Yes

Minimum Water Quality  
Parameters as set by State:

pH 6.8

Print Name: Matt Severloh

Signature:

*Matt Severloh*

Date:

9/2/2025

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>

Email [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us)