



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk mg/L	Y/N
1			
2			
3	7.82	65	Y
4			
5			
6			
7			
8			
9			
10	7.76	67	Y
11	7.79	53	Y
12			
13			
14			
15			
16			
17	7.71	66	Y
18			
19			
20			
21			
22			
23			
24	7.69	67	Y
25	7.83	52	Y
26			
27			
28			
29			
30			
31			
Min	7.69		
Total N's		0	

(No = N = Excursion)

<< Have minimums been met for this day?	ENTRY POINT	
	PWD ID: OR 4100513	

System Name:	Medford Water Commission
Entry Point:	C
Sample Period:	November, 2025

Month/Year

Number of excursions* during this month:

0

(Count the number of days when any WQP was less than the
minimum required)

Total excursions during the previous 5 months:

0

(Over 9 excursions in 6 months is a violation. Entry Point and
Distribution excursions are cumulative)

Is system in compliance?

Yes

Minimum Water Quality
Parameters as set by State:

pH 6.8

Print Name: Matt Severloh

Signature:

Date:

12/1/2025

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>

Email dwp.dmce@state.or.us