



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk mg/L	Y/N	<< Have minimums been met for this day?
1	7.78	66	Y	
2				
3				
4				
5				
6				
7				
8	7.73	65	Y	
9	7.81	53	Y	
10				
11				
12				
13				
14				
15	7.80	64	Y	
16				
17				
18				
19				
20				
21				
22	7.74	66	Y	
23	7.76	55	Y	
24				
25				
26				
27				
28				
29	7.71	65	Y	
30				
31				
Min	7.71			
Total N's		0		

(No = N = Excursion)

ENTRY POINT

PWD ID: OR 4100513

System Name:	Medford Water Commission
Entry Point:	C
Sample Period:	December, 2025

Month/Year

Number of excursions* during this month:

0

(Count the number of days when any WQP was less than the
minimum required)

Total excursions during the previous 5 months:

0

(Over 9 excursions in 6 months is a violation. Entry Point and
Distribution excursions are cumulative)

Is system in compliance?

Yes

Minimum Water Quality
Parameters as set by State:

pH 6.8

Print Name: Matt Severloh

Signature:

Date:

1/5/2026

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>

Email dwp.dmce@state.or.us