



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk mg/L	Y/N
1			
2			
3	7.64	68	Y
4			
5			
6			
7			
8			
9	7.67	67	Y
10			
11			
12			
13			
14			
15			
16	7.73	67	Y
17	7.67	59	Y
18			
19			
20			
21			
22			
23	7.64	67	Y
24			
25			
26			
27			
28			
29			
30	7.67	68	Y
31	7.65	54	Y
Min	7.64		
Total N's			0

<< Have minimums been met for this day?

ENTRY POINT

PWD ID: OR 4100513

System Name:	Medford Water Commission
Entry Point:	C
Sample Period:	March, 2026

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Yes

Minimum Water Quality Parameters as set by State:

pH 6.8

Print Name: Matt Severloh

Signature: *Matt Severloh*

Date: 4/1/2026

(No = N = Excursion)

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>
 Email dwp.dmce@state.or.us