

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID#	Sample Location	рН	Alk	PO4	other	Y/N	<has sample<="" th=""></has>
EP-A	1927 Intake (8/6/2024)	7.90	56				met the minimums?
EP-B	Rogue River (8/6/2024)	7.79	25				
EP-C	East Intake & Springs (8/6/2024)	7.89	51				PWS ID: 41 0 0 5 1 3
EP-A	1927 Intake (8/21/2024)	7.86	50				System Name: Medford Water
EP-B	Rogue River (8/21/2024)	7.86	33				Sample Period: <u>August/2024</u>
	East Intake & Springs (8/21/2024)	7.95	45				Sample Frequency: Monthly
	Antilles (*Not applicable)						Distribution Samples required:
19	Howard (*Not applicable)						
30	Archer (*Not applicable)						Number of excursions during this Sample Period = 0 (Number of locations when any WQP was less than the minimum.)
17	Keenway (*Not applicable)						
39	Fallbrook (*Not applicable)						
21	Antelope (*Not applicable)						
8	Stardust (*Not applicable)						Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.
34	Ave. C (*Not applicable)						
43	Grape (*Not applicable)						
	Samike Drive (*Not applicable)						
	*Not applicable – These sites will be sampled twice the same					For OHA use only	
	Month that our 60 lead and copper samples are taken.					Minimum Water Quality	
							Parameters as set by
							pH 📮
							Alk (Alkalinity)
							PO4 (Orthophosphate)
							Other (Chinophosphate)
							Print Name: Matt Severloh
(N = No = Evourgien) T-4-I NU							Signature: Matt Sevensh
(N = No = Excursion) Total N's						Date: <u>9/3/2024</u>	

Send to Drinking Water Program within 10 days after end of sampling period: OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/