

**Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

ID #	Sample Location	pH	Alk	PO4	other	Y/N
EP-A	1927 Intake (1/8/2025)	7.64	59			
EP-B	Rogue River (1/8/2025)	7.82	62			
EP-C	East Intake & Springs (1/8/2025)	7.66	58			
EP-A	1927 Intake (1/22/2025)	7.84	58			
EP-B	Rogue River (1/22/2025)	7.81	60			
EP-C	East Intake & Springs (1/22/2025)	7.88	59			
40	Antilles (*Not applicable)					
19	Howard (*Not applicable)					
30	Archer (*Not applicable)					
17	Keenway (*Not applicable)					
39	Fallbrook (*Not applicable)					
21	Antelope (*Not applicable)					
8	Stardust (*Not applicable)					
34	Ave. C (*Not applicable)					
43	Grape (*Not applicable)					
N	Samike Drive (*Not applicable)					
*Not applicable – These sites will be sampled twice the same						
Month that our 60 lead and copper samples are taken.						
(N = No = Excursion) Total N's						

<Has sample met the minimums? **DISTRIBUTION**

**PWS ID: 41 0 0 5 1 3**

**System Name: Medford Water**

**Sample Period: January/2025**  
*Month/Year*

**Sample Frequency: Monthly**

**Distribution Samples required: \_\_\_\_\_**

**Number of excursions during this Sample Period = 0**

*(Number of locations when any WQP was less than the minimum.)*

*Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other

**Print Name: Matt Severloh**

**Signature: Matt Severloh**

**Date: 2/4/2025**

Send to Drinking Water Program within 10 days after end of sampling period:  
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>