



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13	7.2	36.6			
14					
15					
16					
17					
18	7.				
19					
20					
21					
22					
23					
24					
25					
26					
27	7.0	35.8			
28					
29					
30					
31					

<<Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41 00525

System Name: Villadom m HP

Entry Point: A

Sample Period: July 2023  
Month/Year

Number of excursions\* during this month: \_\_\_\_\_  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

### Minimum Water Quality Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		( )

Print Name: Emanuel Diaz

Signature: *[Signature]*

Date: 8-10-2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

0