

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12	7.22				
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26	7.20				
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Villadom MHP

Entry Point: A

Sample Period: January / 2022
Month/Year

Number of excursions* during this month: _____

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other

Print Name: Brianne Fave D102

Signature: [Signature]

Date: 2/10/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's