

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.43		0.22		Y
2	7.61				Y
3	7.65				Y
4	7.74		0.28		Y
5	7.76				Y
6	7.75		0.23		Y
7	7.72				Y
8	7.79		0.29		Y
9	7.63				Y
10	7.70				Y
11	7.69				Y
12	7.61				Y
13	7.56		0.25		Y
14	7.53				Y
15	7.50		0.27		Y
16	7.52				Y
17	7.74				Y
18	7.69		0.29		Y
19	7.58				Y
20	7.58				Y
21	7.74				Y
22	7.64		0.31		Y
23	7.61				Y
24	7.63				Y
25	7.59				Y
26	7.53				Y
27	7.43		0.25		Y
28	7.50				Y
29	7.44		0.62		Y
30	7.13				Y
31	7.12				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT
EP-A
PWS ID 4100537
MONMOUTH, CITY OF**

Sample period: March 2024
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0

PO4 TBD (Orthophosphate)

Print Name: Matt Johnson
Signature: 
Date & Phone#: 503-838-2173 4/3/2024

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>