



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.48				Y
2	7.51				Y
3	7.55				Y
4	7.56				Y
5	7.57		0.19		Y
6	7.53				Y
7	7.58		0.18		Y
8	7.42				Y
9	7.41				Y
10	7.38		0.20		Y
11	7.40				Y
12	7.40		0.18		Y
13	7.39				Y
14	7.40		0.19		Y
15	7.56				Y
16	7.58				Y
17	7.42				Y
18	7.38				Y
19	7.40		0.20		Y
20	7.38				Y
21	7.37		0.17		Y
22	7.42				Y
23	7.39				Y
24	7.42				Y
25	7.42				Y
26	7.42		0.19		Y
27	7.44				Y
28	7.44		0.21		Y
29	7.39				Y
30	7.42				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?	County: Polk      Agency: REGION 1
	<b>ENTRY POINT          EP-A          PWS ID 4100537          MONMOUTH, CITY OF</b>
Sample period: <u>June 2024</u> <small>Month/Year</small>	

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

*Reference*

<b>Minimum Water Quality          Parameter(s) as set by State:</b>
pH <input type="text" value="7.0"/>
PO4 <input type="text" value="TBD"/> (Orthophosphate)

**Print Name:** Matt Johnson  
**Signature:**   
**Date & Phone#:** 503-838-2173 7/8/2024

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>