



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.37				Y
2	7.28				Y
3	7.32				Y
4	7.30		0.18		Y
5	7.27				Y
6	7.32		0.16		Y
7	7.32				Y
8	7.35				Y
9	7.33				Y
10	7.35				Y
11	7.33		0.20		Y
12	7.31				Y
13	7.37		0.19		Y
14	7.33				Y
15	7.34				Y
16	7.32				Y
17	7.30				Y
18	7.31		0.22		Y
19	7.34				Y
20	7.33				Y
21	7.37				Y
22	7.35				Y
23	7.28				Y
24	7.26				Y
25	7.33		0.23		Y
26	7.34				Y
27	7.33				Y
28	7.33				Y
29	7.32				Y
30	7.35				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT
EP-A
PWS ID 4100537
MONMOUTH, CITY OF**

Sample period: September 2024
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH

PO4 (Orthophosphate)

Print Name: Matt Johnson
Signature: 
Date & Phone#: 503-838-2173 10/2/2024

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>