



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.32				Y
2	7.31		0.18		Y
3	7.30				Y
4	7.36				Y
5	7.33				Y
6	7.30				Y
7	7.27				Y
8	7.31				Y
9	7.32		0.15		Y
10	7.33				Y
11	7.34				Y
12	7.39				Y
13	7.31				Y
14	7.32				Y
15	7.36				Y
16	7.31		0.16		Y
17	7.32				Y
18	7.34				Y
19	7.30				Y
20	7.35				Y
21	7.31				Y
22	7.33				Y
23	7.30		0.15		Y
24	7.29				Y
25	7.28				Y
26	7.26				Y
27	7.31				Y
28	7.36				Y
29	7.29				Y
30	7.28		0.19		Y
31	7.28				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?	County: Polk Agency: REGION 1
	ENTRY POINT EP-A PWS ID 4100537 MONMOUTH, CITY OF
Sample period:	October 2024 <i>Month/Year</i>

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:
pH <input type="text" value="7.0"/>
PO4 <input type="text" value="0.09"/> (Orthophosphate)

Print Name: Matt Johnson
Signature: 
Date & Phone#: 503-838-2173 11/6/2024

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>