



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.29		0.12		Y
2	7.42				Y
3	7.58				Y
4	7.35				Y
5	7.37				Y
6	7.38		0.11		Y
7	7.39				Y
8	7.41				Y
9	7.35				Y
10	7.35				Y
11	7.36				Y
12	7.37				Y
13	7.34		0.16		Y
14	7.35				Y
15	7.37				Y
16	7.37				Y
17	7.33				Y
18	7.35				Y
19	7.38				Y
20	7.43		0.21		Y
21	7.41				Y
22	7.38				Y
23	7.36				Y
24	7.35				Y
25	7.39				Y
26	7.35		0.30		Y
27	7.42				Y
28	7.44				Y
29	7.45				Y
30	7.41				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT
EP-A
PWS ID 4100537
MONMOUTH, CITY OF**

Sample period: November 2024
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0

PO4 0.09 (Orthophosphate)

Print Name: Matt Johnson
Signature: 
Date & Phone#: 503-838-2173 12/4/2024

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>