



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.32				Y
2	7.36				Y
3	7.33				Y
4	7.41		0.26		Y
5	7.37				Y
6	7.31				Y
7	7.40				Y
8	7.45				Y
9	7.41				Y
10	7.33				Y
11	7.38		0.19		Y
12	7.33				Y
13	7.35				Y
14	7.72				Y
15	7.78				Y
16	7.44		0.16		Y
17	7.33				Y
18	7.35		0.19		Y
19	7.37				Y
20	7.35				Y
21	7.39				Y
22	7.34				Y
23	7.37				Y
24	7.32				Y
25	7.35				Y
26	7.35				Y
27	7.27		0.18		Y
28	7.31				Y
29	7.33				Y
30	7.36				Y
31	7.34				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT
EP-A
PWS ID 4100537
MONMOUTH, CITY OF**

Sample period: December 2024
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH

PO4 (Orthophosphate)

Print Name: Matt Johnson
Signature: 
Date & Phone#: 503-838-2173 1/7/2025

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>