



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.34				Y
2	7.43				Y
3	7.37		0.30		Y
4	7.37				Y
5	7.32		0.32		Y
6	7.36				Y
7	7.38				Y
8	7.17				Y
9	7.33				Y
10	7.20				Y
11	7.21				Y
12	7.20		0.26		Y
13	7.19				Y
14	7.31				Y
15	7.33				Y
16	7.32				Y
17	7.36				Y
18	7.34				Y
19	7.33				Y
20	7.43		0.24		Y
21	7.38				Y
22	7.37				Y
23	7.36				Y
24	7.33				Y
25	7.29				Y
26	7.30		0.29		Y
27	7.31				Y
28	7.36				Y
29	7.40				Y
30	7.38				Y
31	7.37				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

ENTRY POINT
EP-A
PWS ID 4100537
MONMOUTH, CITY OF

Sample period: March 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality
Parameter(s) as set by State:

pH 7.0

PO4 0.09 (Orthophosphate)

Print Name: Matt Johnson
Signature:
Date & Phone#: 503-838-2173 4/2/2025

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>