

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.32				Y
2	7.33				Y
3	7.31				Y
4	7.29				Y
5	7.25				Y
6	7.27				Y
7	7.31		0.20		Y
8	7.26				Y
9	7.29				Y
10	7.23				Y
11	7.24				Y
12	7.30				Y
13	7.29				Y
14	7.28				Y
15	7.26				Y
16	7.24		0.25		Y
17	7.02				Y
18	7.21				Y
19	7.28				Y
20	7.19				Y
21	7.18		0.20		Y
22	7.19				Y
23	7.26				Y
24	7.29				Y
25	7.26				Y
26	7.29				Y
27	7.30				Y
28	7.33		0.20		Y
29	7.31				Y
30	7.32				Y
31	7.31				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

ENTRY POINT
EP-A
PWS ID 4100537
MONMOUTH, CITY OF

Sample period: May 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0

PO4 0.09 (Orthophosphate)

Print Name: Matt Johnson

Signature: 

Date & Phone#: 503-838-2173 6/2/2025

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>