

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.25				Y
2	7.26		0.21		Y
3	7.27				Y
4	7.18				Y
5	7.17				Y
6	7.14				Y
7	7.20				Y
8	7.26				Y
9	7.28		0.17		Y
10	7.25				Y
11	7.26		0.21		Y
12	7.21				Y
13	7.25				Y
14	7.26		0.22		Y
15	7.25				Y
16	7.25				Y
17	7.25				Y
18	7.27				Y
19	7.17				Y
20	7.26				Y
21	7.20				Y
22	7.22				Y
23	7.24		0.22		Y
24	7.29				Y
25	7.28				Y
26	7.25				Y
27	7.23				Y
28	7.21				Y
29	7.27				Y
30	7.28		0.21		Y
31	7.26				Y
(No = N = Excursion) Total N's					0

<<Have
minimums
been met for
this day?

County: Polk Agency: REGION 1

ENTRY POINT
EP-A
PWS ID 4100537
MONMOUTH, CITY OF

Sample period: July 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0

PO4 0.09 (Orthophosphate)

Print Name: Matt Johnson

Signature: 

Date & Phone#: 503-838-2173 8/7/2025

Send to DWP within 10 days after end of
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>