

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.19		0.17		Y
2	7.20				Y
3	7.22				Y
4	7.19				Y
5	7.21				Y
6	7.20				Y
7	7.18				Y
8	7.19		0.20		Y
9	7.19				Y
10	7.21				Y
11	7.20				Y
12	7.21				Y
13	7.19				Y
14	7.20				Y
15	7.21		0.19		Y
16	7.23				Y
17	7.02				Y
18	7.17				Y
19	7.15				Y
20	7.22				Y
21	7.21				Y
22	7.20		0.18		Y
23	7.21				Y
24	7.20				Y
25	7.19				Y
26	7.22				Y
27	7.21				Y
28	7.22				Y
29	7.20		0.18		Y
30	7.22				Y
31	7.21				Y
(No = N = Excursion) Total N's					0

<<Have
minimums
been met for
this day?

County: Polk Agency: REGION 1

ENTRY POINT
EP-A
PWS ID 4100537
MONMOUTH, CITY OF

Sample period: October 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0

PO4 0.09 (Orthophosphate)

Print Name: Matt Johnson

Signature: 

Date & Phone#: 503-838-2173 11/5/2025

Send to DWP within 10 days after end of
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>