



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.39				Y
2	7.28				Y
3	7.40				Y
4	7.50				Y
5	7.37				Y
6	7.51				Y
7	8.05		0.34		Y
8	7.87				Y
9	7.33				Y
10	7.36				Y
11	7.31				Y
12	7.46				Y
13	7.36				Y
14	7.43		0.29		Y
15	7.46				Y
16	7.48				Y
17	7.52				Y
18	7.46				Y
19	7.48				Y
20	7.52				Y
21	7.55		0.53		Y
22	7.47				Y
23	7.44				Y
24	7.44				Y
25	7.54				Y
26	7.39				Y
27	7.56				Y
28	7.60		0.26		Y
29	7.57				Y
30	7.55				Y
31	7.52				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?	County: Polk Agency: REGION 1 <p style="text-align: center;">ENTRY POINT EP-A PWS ID 4100537 MONMOUTH, CITY OF</p>
Sample period: <u>January 2026</u> <small>Month/Year</small>	

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

<p>Minimum Water Quality Parameter(s) as set by State:</p> <p>pH <input type="text" value="7.0"/></p> <p>PO4 <input type="text" value="0.09"/> (Orthophosphate)</p>
--

Print Name: Matt Johnson
Signature: 
Date & Phone#: 503-838-2173 2/2/2026

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>