



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.53				Y
2	7.56				Y
3	7.45				Y
4	7.37		0.29		Y
5	7.36				Y
6	7.43				Y
7	7.40				Y
8	7.42				Y
9	7.49				Y
10	7.49				Y
11	7.51				Y
12	7.38				Y
13	7.40				Y
14	7.28				Y
15	7.34				Y
16	7.32				Y
17	7.31				Y
18	7.46		0.29		Y
19	7.31				Y
20	7.24				Y
21	7.48				Y
22	7.53				Y
23	7.43				Y
24	7.53				Y
25	7.47		0.28		Y
26	7.42				Y
27	7.45				Y
28	7.43				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT
EP-A
PWS ID 4100537
MONMOUTH, CITY OF**

Sample period: February 2026
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH

PO4 (Orthophosphate)

Print Name: Matt Johnson
Signature: 
Date & Phone#: 503-838-2173 3/10/2026

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>