



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.46				Y
2	7.30				Y
3	7.52				Y
4	7.45		0.26		Y
5	7.50				Y
6	7.53				Y
7	7.54				Y
8	7.40				Y
9	7.19				Y
10	7.41				Y
11	7.48		0.34		Y
12	7.54				Y
13	7.34				Y
14	7.45				Y
15	7.42				Y
16	7.41				Y
17	7.40				Y
18	7.41		0.33		Y
19	7.39				Y
20	7.31				Y
21	7.33				Y
22	7.31				Y
23	7.33		0.30		Y
24	7.30				Y
25	7.33				Y
26	7.32				Y
27	7.35		0.31		Y
28	7.19				Y
29	7.31				Y
30	7.32				Y
31	7.31				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

County: Polk Agency: REGION 1

**ENTRY POINT
 EP-A
 PWS ID 4100537
 MONMOUTH, CITY OF**

Sample period: March 2026
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
 Parameter(s) as set by State:**

pH

PO4 (Orthophosphate)

Print Name: Matt Johnson
Signature: 
Date & Phone#: 503-838-2173 4/2/2026

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>