

Water Quality Parameter Monitoring Form

LCR-Corrosion Control

County: Polk

Sample Period (Month/Yr.): January 2021

Agency: Region 1

System: City of Monmouth

PWS ID: 41 00537

Day	pH	Alk.	PO4	Si	Y/N	<input type="checkbox"/> < Have minimums been met for this Day?
1	7.6				Y	Entry Point: EP-A Sampling Location: Entry Point Monitoring Frequency: Three times per week Number of required Distribution Monitoring Sites: 0 State Minimum Parameter Levels Point of entry Distribution pH: 7.0 su pH: N/A su Alkalinity: N/A mg/l Alkalinity: N/A mg/l Phosphate: N/A mg/l Phosphate: N/A mg/l Note: Over 9 excursions in 6 months is a violation. (Entry point and Distribution excursions are cumulative). An "excursion" is any day in which the water quality Parameter(s) fall below the minimum set by the state.
2	7.7				Y	
3	7.6				Y	
4	7.6				Y	
5	7.5				Y	
6	7.4				Y	
7	7.4				Y	
8	7.4				Y	
9	7.4				Y	
10	7.4				Y	
11	7.4				Y	
12	7.4				Y	
13	7.3				Y	
14	7.4				Y	
15	7.4				Y	
16	7.3				Y	
17	7.5				Y	
18	7.5				Y	
19	7.5				Y	
20	7.5				Y	
21	7.5				Y	
22	7.5				Y	
23	7.4				Y	
24	7.4				Y	
25	7.1				Y	
26	7.1				Y	
27	7.3				Y	
28	7.5				Y	
29	7.4				Y	
30	7.5				Y	
31	7.5				Y	
Total Number of Excursions this Month:						0

Print Name: Matthew Johnson

Phone: (503) 838-2173

Signature: 

Date: 2/4/2021