

Water Quality Parameter Monitoring Form

LCR-Corrosion Control

County: Polk Sample Period (Month/Yr.): February 2021 Agency: Region 1
 System: City of Monmouth PWS ID: 41_00537

Day	pH	Alk.	PO4	Si	Y/N	<input type="checkbox"/> < Have minimums been met for this Day?	
1	7.4				Y	Entry Point: EP-A Sampling Location: Entry Point Monitoring Frequency: Three times per week Number of required Distribution Monitoring Sites: 0 State Minimum Parameter Levels	
2	7.4				Y		
3	7.4				Y		
4	7.4				Y		
5	7.4				Y		
6	7.3				Y		
7	7.5				Y		
8	7.5				Y	Point of entry	Distribution
9	7.2				Y	pH: 7.0 su	pH: N/A su
10	7.3				Y	Alkalinity: N/A mg/l	Alkalinity: N/A mg/l
11	7.5				Y	Phosphate: N/A mg/l	Phosphate: N/A mg/l
12	7.7				Y	Note: Over 9 excursions in 6 months is a violation. (Entry point and Distribution excursions are cumulative). An "excursion" is any day in which the water quality Parameter(s) fall below the minimum set by the state. Send to OHA-DWP within 10 days after end of sampling period: OHA - Drinking Water Program PO Box 14350 Portland, OR 97293-0350 Phone: (971) 673-0405 Website: http://healthoregon.org/dwp/	
13	7.6				Y		
14	7.6				Y		
15	7.6				Y		
16	7.4				Y		
17	7.4				Y		
18	7.4				Y		
19	7.4				Y		
20	7.4				Y		
21	7.4				Y		
22	7.4				Y		
23	7.5				Y		
24	7.4				Y		
25	7.4				Y		
26	7.4				Y		
27	7.4				Y		
28	7.4				Y		
Total Number of Excursions this Month:						0	

Print Name: Matthew Johnson Phone: (503) 838-2173
 Signature:  Date: 3/5/2021